



NOTE 1: CHIMNEY SERVICE LATERALS SHALL BE INSTALLED ON ALL LINES 15' DEEP OR GREATER

NOTE 2: COMPRESSION JOINTS FOR VCP SHALL MEET ASTM C-425

NOTE 3: SUITABLE TOILET FACILITIES, IN COMPLIANCE WITH THE UNIFORM PLUMBING CODE, MUST BE INSTALLED, AT THE OWNERS EXPENSE, IN ANY PROPERTY THAT CONNECTS TO THE PUBLICLY OWNED SEWER

NOTE 4: ALL WORK DONE MUST BE INSPECTED AND APPROVED BY CVWD

CRESCENTA VALLEY WATER DISTRICT



SCALE: NTS	STANDARD CHIMNEY LATERAL	DATE: 03/14/2008	
DRAWN BY: B. YARED		JOB NO.	DWG NO.
APP'VD BY: D. GOULD		-	11-S