



PIPE DIAMETER	CLASS A MAX. DEPTH	CLASS B MAX. DEPTH
8"	20'	30'
10"	19'	30'
12"	16'	21.5'

NOTE 1: BEDDING SHALL BE DONE PER SECTION 306-1.2.1 OF SSPWC FOR CLASS A BEDDING AND BACKFILL USED SHALL BE OF SUCH PARTICLE SIZE THAT 90-100% WILL PASS A NO. 4 SIEVE IN ACCORDANCE WITH ASTM C136 AND SSPWC, SECT. 306-1.2.1. CAN BE USED AS BEDDING IF DEPTH IS NO GREATER THAN 12'.

NOTE 2: ALL BACKFILL SHALL BE IMPORTED AND CONFORM TO SSPWC, SECT. 306-1.3.7 UNLESS OTHERWISE STIPULATED IN CONTRACT DOCUMENTS.

NOTE 3: $W_{MAX} = 8" + OD/2$

CRESCENTA VALLEY WATER DISTRICT



SCALE: NTS	TRENCH AND BACKFILL STANDARD	DATE: 03/14/2008	
DRAWN BY: B. YARED		JOB NO.	DWG NO.
APP'VD BY: D. GOULD		-	40-S