



NOTE 1: ALL CONNECTIONS TO THE CVWD WASTE WATER COLLECTIONS SYSTEM MUST BE DONE USING A PREFABRICATED WYE FITTING

NOTE 2: WYE PIPE BRANCH FASTENING MATERIAL SUCH AS EPOXY RESIN OR OTHER ACCEPTED MATERIAL SHALL HAVE STRENGTH EQUAL TO THE PIPE MATERIAL

NOTE 3: COMPRESSION JOINTS AND COUPLINGS FOR VCP SHALL MEET ASTM C425

NOTE 4: REMOVED PIPING SECTION MUST BE CUT CLEANLY AND ALL MATERIAL MUST BE DISPOSED OF PROPERLY

NOTE 5: ALL WORK DONE MUST BE INSPECTED AND APPROVED BY CVWD

CRESCENTA VALLEY WATER DISTRICT



SCALE: NTS	STANDARD CONNECTION INTO EXISTING SEWER	DATE: 4/18/2008	
DRAWN BY: B YARED		JOB NO.	DWG NO.
APP'VD BY: D GOULD		-	50-S